



PRODUCT PERFORMANCE RATING

Document ID 052520211432-23704530

Issued on 25 May 2021

This product is certified by Eurovent Certita Certification as mentioned on

Certificate N° 03.01.247

This document is valid at the date of issue - **Check the current validity on www.eurovent-certification.com**

Product	Air Conditioners / Climatiseurs (AC)
Product type	Comfort air conditioner below 12 kW/ air-cooled/ split/ reversible
Brand	AIRWELL
Range	HKD
Product référence	AW-YKD009-H91/AW-HKD009-N91

This performance certificate is delivered for the following project:

Project Name	Company	Project reference	Project location
Home		VH	Belarus

FEATURE	VALUE	UNIT
STANDARD COOLING/COOLING PL COND A		
Pc	2.70	kW
Pec	0.73	kW
EER	3.68	



PRODUCT PERFORMANCE RATING

Document ID 052520211432-23704530

Issued on 25 May 2021

This product is certified by Eurovent Certita Certification as mentioned on

Certificate N° 03.01.247

This document is valid at the date of issue - **Check the current validity on www.eurovent-certification.com**

FEATURE	VALUE	UNIT
STANDARD HEATING		
Ph	3.61	kW
Peh	0.95	kW
COP	3.79	

FEATURE	VALUE	UNIT
ACOUSTIC		
LwO env	61	dB(A)
LwI1 env	53	dB(A)

FEATURE	VALUE	UNIT
COOLING PL CONDB		
Pc @ 30°C	2.07	kW
EER @ 30°C	5.59	



PRODUCT PERFORMANCE RATING

Document ID 052520211432-23704530

Issued on 25 May 2021

This product is certified by Eurovent Certita Certification as mentioned on

Certificate N° 03.01.247

This document is valid at the date of issue - **Check the current validity on www.eurovent-certification.com**

FEATURE	VALUE	UNIT
COOLING PL CONDC		
Pc @ 25°C	1.33	kW
EER @ 25°C	8.12	

FEATURE	VALUE	UNIT
COOLING PL CONDD		
Pc @ 20°C	1.18	kW
EER @ 20°C	11.75	

FEATURE	VALUE	UNIT
SEASONAL EFFICIENCY IN COOLING		
Pdesignc	2.70	kW
SEER	6.70	
Qce	141.00	kWh/annum
SEER Class	A++	



PRODUCT PERFORMANCE RATING

Document ID 052520211432-23704530

Issued on 25 May 2021

This product is certified by Eurovent Certita Certification as mentioned on

Certificate N° 03.01.247

This document is valid at the date of issue - **Check the current validity on www.eurovent-certification.com**

FEATURE	VALUE	UNIT
HEATING PL CONDA		
Ph @ -7°C	1.92	kW
COP @ -7°C	3.06	

FEATURE	VALUE	UNIT
HEATING PL CONDB		
Ph @ +2°C	1.24	kW
COP @ 2°C	4.21	

FEATURE	VALUE	UNIT
HEATING PL CONDC		
Ph @ +7°C	0.79	kW
COP @ +7°C	4.61	

FEATURE	VALUE	UNIT
HEATING PL CONDD		
Ph @ +12°C	0.71	kW
COP @ +12°C	5.54	



PRODUCT PERFORMANCE RATING

Document ID 052520211432-23704530

Issued on 25 May 2021

This product is certified by Eurovent Certita Certification as mentioned on

Certificate N° 03.01.247

This document is valid at the date of issue - **Check the current validity on www.eurovent-certification.com**

FEATURE	VALUE	UNIT
HEATING AVERAGE CLIMATE		
Pdesignh	2.20	kW
SCOP	4.10	
SCOP Class	A+	
Qhe	751.00	kWh/annum

FEATURE	VALUE	UNIT
BIVALENT POINT		
Tbiv	-7	°C
COP @ Tbiv	3.06	
Ph TBiv	1.92	kW

FEATURE	VALUE	UNIT
TOL RUNING TEST		
TOL	-10.00	°C
Ph @ TOL	2.46	kW
COP @ TOL	2.67	



PRODUCT PERFORMANCE RATING

Document ID 052520211432-23704530

Issued on 25 May 2021

This product is certified by Eurovent Certita Certification as mentioned on

Certificate N° 03.01.247

This document is valid at the date of issue - **Check the current validity on www.eurovent-certification.com**

FEATURE	VALUE	UNIT
POFFC		
Poff	2.00	W

FEATURE	VALUE	UNIT
PSBC		
Psb	2.00	W

FEATURE	VALUE	UNIT
PTOC		
Pto	22.00	W

FEATURE	VALUE	UNIT
POFFH		
Poffh	2.00	W

FEATURE	VALUE	UNIT
PSBH		
Psbh	2.00	W



PRODUCT PERFORMANCE RATING

Document ID 052520211432-23704530

Issued on 25 May 2021

This product is certified by Eurovent Certita Certification as mentioned on

Certificate N° 03.01.247

This document is valid at the date of issue - **Check the current validity on www.eurovent-certification.com**

FEATURE	VALUE	UNIT
PTOH		
Ptoh	22.00	W

FEATURE	VALUE	UNIT
GENERAL		
Capacity Control	Variable	
Main Power Supply	230-1-40	
Refrigerant	R32	
Refr. Line	5 m	m
Mounting	Wall mounted	